

**Government of Jammu and Kashmir**  
**Office of the Regional Director J&K State Pollution Control Board**  
**Parivesh Bhawan, Forest Complex, Gladni, Transport Nagar,**  
**Narwal, Jammu**

.....

**Block Medical Officer,**  
**Government Primary Health Centre,**  
**Afti, Warwan, Kishtwar**

No. SPCB/RDJ/BMWM/Notice/2016/3027-30

Dated: 27-08-2016

**Subject:** Notice for violation of Water (Prevention and Control of Pollution) Act 1974, the Air (Prevention and Control of Pollution) Act 1981, and the Bio-medical Waste Management Rules, 2016 by **Government Primary Health Centre, Afti, Warwan, Kishtwar**

1. Whereas hospitals having total waste water generation more than 100 kilolitres per day or/and hospitals having captive incinerator, have been classified as a **RED** category activity in the latest classification of industrial sectors notified by the Central Pollution Control Board. Hospitals having total waste-water generation less than 100 kilolitres per day and without incinerator fall under **ORANGE** category.
2. Whereas hospitals are included in the list of activities that require **consent to establish/operate** from the State Pollution Control Board under section 25/26 of the Water (Prevention and Control of Pollution) Act, 1974 and section 21 of the Air (Prevention and Control of Pollution) Act, 1981.
3. Whereas, the Hospital mentioned in the subject above **is operating without consent** from the J&K SPCB under the Water/Air Acts.
4. Whereas failure to comply with the provisions of section 21 of the Air (Prevention and Control of Pollution) Act, 1981 and section 25/26 of the Water (Prevention and Control of Pollution) Act, 1974 **is punishable with imprisonment and fine** under relevant sections of the respective Acts.
5. Whereas, under the Biomedical Waste Management Rules, 2016, standards have been prescribed for discharging waste water generated from health care facilities into sewer as follows:

<b>Parameters</b>	<b>Permissible limits</b>
pH	6.5-9.0
Suspended solids	100 mg/l
Oil and Grease	10 mg/l
BOD	30 mg/l
COD	250 mg/l
Bio-assay test	90 % survival of fish after 96 hours in 100 % effluent.

