



J&K STATE POLLUTION CONTROL BOARD
Jammu /Srinagar (www.jkspcb.nic.in)

CONSENT ORDER

SPCB --- 822 --- of 2016 dated 23-12-2016

Consent to Establish (Fresh for additional rooms) under section 25/26 of the Water (Prevention & Control of Pollution) Act, 1974, and under section 21 of the Air (Prevention & Control of Pollution) Act, 1981, as amended is granted in favour of

Smt. Marayam Begum

M/s Hotel Forest View
Karlah Padora Enclave Patnitop Udhampur

for a period upto **August 2017** for a category of **Orange** as per revised classification of industrial sector, subject to the following terms and conditions in a time bound manner:

1. The consent granted by the Board is restricted to Prevention and Control of Pollution only and shall not be treated as substitute of permission required under other laws of the land.
2. The consent is granted valid for the establishment of hotel / restaurant as under with capital investment as per schedule I Rs. 19.30 lacs.

S.No.	Hotel / Restaurant Facility	Capacity
1	Rooms	04 Nos.

The emissions or discharge of environmental pollutants from the hotel shall not exceed the relevant parameters and standards specified under respective schedules of the Environment (Protection) Rules, 1986 as amended from time to time.

3. Compliance under Water Act :

a. Effluent standards of discharge of treated effluent

Treatment : The hotel owner has to operate and maintain a comprehensive effluent treatment system consisting of Primary / Secondary and / or Tertiary treatment so as to achieve the quality of the treated effluent to the following standards of discharge outlet.

Parameters	Conc. in mg/l except for pH
PH	5.5 to 9.0
Total Suspended Solids	50
BOD(3 days at 27°C) Formulation	30
Oil & Grease	10
Phosphate as P	1.0

b. Standards for discharge of sewerage treatment

Sewage Treatment – The hotel owner shall install a comprehensive treatment system as is warranted with reference to effluent quality and operate and maintain the same continuously so as to achieve the quality of treated effluent to the following standards before disposal :-

Parameters	Range	Conc. in mg/l except for pH
pH	between	6-9
Suspended Solids	Not to exceed	100 mg/l
BOD, 3 days, 27°C	Not to exceed	30 mg/l

c. All the domestic waste water is disposed off through sewage treatment plant .

d. Water consumption

- i. The daily quantity of sewage effluent from the unit shall not exceed 03KLD
- ii. The daily quantity of water consumption shall not exceed 05 KLD.

4. Compliance under Air Act:

- a. The hotel owner shall comply to **National Ambient Air Quality Standards** as per EP Act 1986 (refer rule 3(3B) .

