



J&K STATE POLLUTION CONTROL BOARD

Jammu /Srinagar (www.jkspcb.nic.in)

CONSENT ORDER

SPCB 1162 of 2017 dated 03-3-2017

Consent to **Operate (Renewal)** under section 25/26 of the Water (Prevention & Control of Pollution) Act,1974, and under section 21 of the Air (Prevention & Control of Pollution) Act,1981, as amended is granted in favour of

Sh. Nanu Ram Aggarwal

M/s Bhawani Wire & Cable

Lane 3 SIDCO Industrial Complex Bari Brahamana

for a period upto **September 2019** for **Red** category of unit as per revised classification of industrial sector, subject to the following terms and conditions in a time bound manner:

1. The consent granted by the Board is restricted to Prevention and Control of Pollution only and shall not be treated as substitute of permission required under other laws of the land.
2. The consent is granted valid for the manufacture of the products / by-products consented quantity as under with capital investment as per schedule II **Rs. 56.25 lacs**. Any change / enhancement in production capacity , process , raw materials shall have be intimated to the board and unit holder has to apply fresh for the same

S.No.	Products / By-product	Maximum Quantity
1	Lead Ingots	4800 MT/annum
2	Pig Lead Ingots	2400 MT/annum

(The unit is registered vide DIC vide No: 07/04/09649/PMT dt: 30-10-2006)

The emissions or discharge of environmental pollutants from the unit / establishment shall not exceed the relevant parameters and standards for the said industry, operation or process specified under respective schedules of the Environment (Protection) Rules , 1986 as amended from time to time.

3. Compliance under Water Act :

a. Standards of discharge for Trade Effluent :

Treatment : The unit holder has to operate and maintain a comprehensive effluent treatment system consisting of Primary / Secondary and / or Tertiary treatment so as to achieve the quality of the treated effluent to the following standards of discharge outlet.

Parameters	Conc. in mg/l except for pH
pH	6.5-8.5
Suspended Solids	100
BOD(3 days at 270 c)	30
COD	250
Oil & Grease	10

b. Standards of discharge for Sewerage disposal:

Sewage Treatment – The unit holder has to install a comprehensive treatment system as is warranted with reference to effluent quality and operate and maintain the same continuously so as to achieve the quality of treated effluent to the following standards before disposal :-

Parameters	Range	Conc. in mg/l except for pH
pH	between	6-9
Suspended Solids	Not to exceed	100
BOD, 3 days, 27°C	Not to exceed	30

c. All the domestic waste water is disposed off through septic tank and soakage pit.

d. Water consumption

- i. The daily quantity of sewage effluent from the unit shall not exceed 0.45 KLD
- ii. The daily quantity of water consumption shall not exceed 1.5 KLD.

