



**J&K STATE POLLUTION CONTROL BOARD**  
**Jammu / Srinagar (www.jkspcb.nic.in)**

**CONSENT ORDER**

SPCB 1165 of 2017 dated 03-3-2017

Consent to Operate (Renewal) under section 25/26 of the Water (Prevention & Control of Pollution) Act, 1974, and under section 21 of the Air (Prevention & Control of Pollution) Act, 1981, as amended is granted in favour of Sh. Atul Patel (Plant Head)

**M/s Lupin Ltd.**

**EPIP Kartholi SIDCO Bari Brahamana**

for a period upto **March 2022** for **Orange** category of as per revised classification of industrial sector, subject to the following terms and conditions in a time bound manner:

1. The consent granted by the Board is restricted to Prevention and Control of Pollution only and shall not be treated as substitute of permission required under other laws of the land.
2. The consent is granted valid for the manufacture of the products / by-products consented quantity as under with capital investment as per schedule II Rs. 7216.30 lacs . Any change / enhancement in production capacity , process , raw materials shall have be intimated to the board and unit holder has to apply fresh for the same

S.No.	Products / By-product	Maximum Quantity
1	<b>Pharmaceutical Formulation:</b> Tablets	234.5 Crore Nos. /annum
2	Capsules	79 Crore Nos. /annum
3	Inhaler	89.10 lacs Nos. /annum
		(As per DIC assessment vide No. 9841-Ind/11868-71 dt: 13-3-2013)

(The unit is registered vide DIC vide No: MSU/2006/96 dt: 16-6-2006)

The emissions or discharge of environmental pollutants from the unit / establishment shall not exceed the relevant parameters and standards for the said industry, operation or process specified under respective schedules of the Environment (Protection) Rules , 1986 as amended from time to time.

**3. Compliance under Water Act :**

**a. Standards of discharge for Trade Effluent:**

**Treatment :** The unit holder has to operate and maintain a comprehensive effluent treatment system consisting of Primary / Secondary and / or Tertiary treatment so as to achieve the quality of the treated effluent to the following standards of discharge outlet.

Compulsory Parameters	Conc. in mg/l except for pH
PH	6.0-8.5
Total Suspended Solids	100
BOD(3 days at 270 c )Formulation	100
COD	250
Oil & Grease	10
Bioassay Test	90% survival of fish after first 96 hr. in 100% effluent
Additional Parameters	Conc. in mg/l except for pH
Mercury	0.01
Arsenic	0.20
Chromium (Cr)	0.10
Lead	0.10
Cyanide	0.10
Phenolics (C <sub>6</sub> H <sub>5</sub> OH)	1.0
Sulphides (as S)	2.0
Phosphate (as P)	5.0

