



# J&K STATE POLLUTION CONTROL BOARD

Jammu /Srinagar (www.jkspcb.nic.in)

## CONSENT ORDER

SPCB 1168 of 2017 dated 03/03/2017

Consent to **Operate (Renewal)** under section 25/26 of the Water (Prevention & Control of Pollution) Act,1974, and under section 21 of the Air (Prevention & Control of Pollution) Act,1981, as amended is granted in favour of Nazir Ahmad Shora

M/s Embassy Hotel  
Khonkhan Dalgate Srinagar

for a period upto **August 2019** for **Orange** category of hotel as per revised classification of industrial sector, subject to the following terms and conditions in a time bound manner:

1. The consent granted by the Board is restricted to Prevention and Control of Pollution only and shall not be treated as substitute of permission required under other laws of the land.
2. The consent is granted valid for operating the hotel / restaurant facility .

S.No.	Hotel / Restaurant Facility	Capacity
1	Bed Rooms	49 Nos.

The emissions or discharge of environmental pollutants from the hotel shall not exceed the relevant parameters and standards specified under respective schedules of the Environment (Protection) Rules , 1986 as amended from time to time.

### 3. Compliance under Water Act :

#### a. Standards of discharge for Trade effluent:

**Treatment :** The hotel owner has to operate and maintain a comprehensive effluent treatment system consisting of Primary / Secondary and / or Tertiary treatment so as to achieve the quality of the treated effluent to the following standards of discharge outlet.

Parameters	Conc. in mg/l except for pH
PH	5.5 to 9.0
Total Suspended Solids	50
BOD(3 days at 270 c )	30
Oil & Grease	10
Phosphate as P	1.0

#### b. Standards of discharge for Sewerage disposal:

**Sewage Treatment** – The hotel owner has to install a comprehensive treatment system as is warranted with reference to effluent quality and operate and maintain the same continuously so as to achieve the quality of treated effluent to the following standards before disposal :-

Parameters	Range	Conc. in mg/l except for pH
pH	between	6-9
Suspended Solids	Not to exceed	100
BOD, 3 days, 27°C	Not to exceed	30

c. All the domestic waste water is disposed off through sewage treatment plant .

#### d. Water consumption

- i. The daily quantity of sewage effluent from the unit shall not exceed 12 KLD
- ii. The daily quantity of water consumption shall not exceed 20 KLD.

### 4. Compliance under Air Act:

- a. The hotel owner shall comply to **National Ambient Air Quality Standards** as per EP Act 1986 (refer rule 3(3B) .

