

J&K State Pollution Control Board
Transport Nagar Narwal Gladni Jammu

Dr. R.P. Kudyar
Director Principal
Achrya Shri Chander College of
Medical Sciences & Hospital
Sidhra Jammu

NO:- SPCB/T/BMW/55/ 939-40

Dated:- 20/2/2016.


Subject:- Application for authorization (renewal) under Bio-Medical Waste (Management & Handling) Rules 1998.

Sir,

While examining your case for grant of Authorization under Bio- Medical Waste (M & H) Rules 1998 it has been observed that:-

1. Emergency and central laboratory improper segregation and labelling was found in these areas.
2. Blood Bank:-Colour coding, mutilation,disinfection & labelling is being fallowed. However of bio medical with general waste was found at certain points.
3. Wards:-In wards, needle destroy units, colour coded bins & scissors for mutilation of plastic waste (cat.07) are installed but segregation at source is not being fallowed.
4. Incineration Area:-The area for collection of bio medical waste to be incinerated has been designated. Room for storage of incineration ash has also been designated. However, the stack height of 30 meter has not been maintained.
5. The hospital authorities have installed a shredder for mutilation of plastic waste.
6. The hospital authorities need to further improve management of Municipal Solid Waste generated as per Municipal Solid Waste (Management & Handling) Rules.
7. Sewage Treatment Plant (STP):- The area was found non-operational at the time of inspection.
8. The hospital needs to submit self monitoring report of incinerator,D.G.sets and of STP whenever fully operational and mock drill report of the fire hydrant system.

In this connection you are directed to rectify the above shortcomings within **one month** otherwise your case for authorization is rejected/refused.


19/2/16
Member Secretary

Copy to the:-

Regional Director State Pollution Control Board, Jammu for information and necessary action.