



J&K STATE POLLUTION CONTROL BOARD

Jammu / Srinagar (www.jkspcb.nic.in)

CONSENT ORDER

SPCB 555 of 2017 dated 21-11-2017

Consent to Operate (Renewal) under section 25/26 of the Water (Prevention & Control of Pollution) Act, 1974, and under section 21 of the Air (Prevention & Control of Pollution) Act, 1981, as amended is granted in favour of

Gh. Mohi-ud-din

M/s Hotel Rainbow,
Indra Nagar, Srinagar

for a period upto **January 2022 (extended consent)** for a category of **Orange** as per revised classification of industrial sector, subject to the following terms and conditions in a time bound manner:

1. The consent granted by the Board is restricted to Prevention and Control of Pollution only and shall not be treated as substitute of permission required under other laws of the land.
2. The consent is granted for operation of hotel / restaurant facility.

S.No.	Hotel / Restaurant Facility	Capacity
1	Rooms	26 Nos' (with attached bathrooms)

The emissions or discharge of environmental pollutants from the hotel shall not exceed the relevant parameters and standards specified under respective schedules of the Environment (Protection) Rules, 1986 as amended from time to time.

3. Compliance under Water Act :

a. Standards of discharge for Trade effluent

Treatment: The hotel owner has to operate and maintain a comprehensive effluent treatment system consisting of Primary / Secondary and / or Tertiary treatment so as to achieve the quality of the treated effluent to the following standards of discharge outlet.

Parameters	Conc. in mg/l except for pH
PH	5.5 to 9.0
Total Suspended Solids	50
BOD(3 days at 270 c)Formulation	30
Oil & Grease	10
Phosphate as P	1.0

b. Standards of discharge for Sewerage disposal :

Sewage Treatment – The hotel owner has to install a comprehensive treatment system as is warranted with reference to effluent quality and operate and maintain the same continuously so as to achieve the quality of treated effluent to the following standards before disposal :-

Parameters	Range	Conc. in mg/l except for pH
pH	between	6-9
Suspended Solids	Not to exceed	100
BOD, 3 days, 27°C	Not to exceed	30

c. All the domestic waste water is disposed off through sewage treatment plant.

d. Water consumption

- i. The daily quantity of sewage effluent from the hotel shall not exceed 25 KLD.
- ii. The daily quantity of water consumption shall not exceed the approved permissible quantity.

Boh

