

Government of Jammu & Kashmir
J&K State Pollution Control Board
Rajbagh Srinagar.

Sh Ramesh Chander Sharma(Prop)
M/s Hotel Durga Bus Stand Katra
District Reasi.

No:- PCB/T/C/79 / 609 - 11


Dated:- 06-06-2016

Sub:- Application for grant of Consent to Operate (Fresh) in favour of M/s Hotel Durga Bus Stand Katra District Reasi.

While examining your application for Consent to Operate (Fresh), in favour of M/S Hotel Durga Bus Stand Katra, it was observed that:-

- I. The Sewerage Treatment Plant of your hotel is not operational.
- II. Suction hood in kitchen is not installed.

As such, your application for grant of Consent to Operate (Fresh) is considered and rejected. Accordingly You are provided an opportunity to rectify the shortcomings given above, and report compliance through the concerned District Officer/Regional Director (Jammu) within **six weeks**. In case you fail to comply with the requirements above, your application for grant of consent to Operate (fresh) will be refused and closure order under environmental laws shall follow.


6/6/16
Member Secretary.

Copy to the:-

1. Regional Director ,PCB.Jammu for information and necessary action.
2. District officer PCB Reasi for inf and n/a.