

Govt of Jammu and Kashmir
J&K State Pollution Control Board
Behind Silk Factory Rajbagh Srinagar

Sh. Manzoor Ahmad (Prop)
M/S Hotel Lehchen
Yourthong Leh

No: SPCB/T/C/ 123/552. dated: 02-06-2016

Subject:- Consent to operate Fresh in favour of M/S Hotel Lehchen, Yourthong Leh.

While examining your case for issuance of consent to operate fresh infavour of M/S Hotel Lehchen Yourthong Leh, it has been observed that no Sewerage Treatment Plant is installed in your Hotel for treatment of waste water, which is mandatory for the Hotel having capacity more than 19 rooms.

As such you are advised to install Sewerage Treatment Plant of 20 KLD capacity in your hotel and inform this office through Nodal officer leh for further necessary action within one month .


1/6/16
Member Secretary